Gas Station Fire Safety Checklist (US)

Safety & Compliance | US

DATE	INSPECTOR	STATION / FACILITY ID
____ / ____ / _____		

FIRE EXTINGUISHERS

	OK	NOT OK	N/A
Extinguishers at each dispenser island *NFPA 30A — max 75 ft travel distance*	○	○	○
Extinguishers in store and office	○	○	○
Gauges in green zone	○	○	○
Safety pins and seals intact	○	○	○
Annual inspection tags current	○	○	○
Not obstructed, visible from pumps	○	○	○

EMERGENCY SHUT-OFF SYSTEMS

	OK	NOT OK	N/A
Emergency stop buttons accessible *NFPA 30A 6.7 — clearly identified, readily accessible*	○	○	○
E-stop locations clearly marked	○	○	○
Shear valves intact on dispensers	○	○	○
Main fuel shut-off valve accessible	○	○	○

ELECTRICAL SAFETY

	OK	NOT OK	N/A
No damaged wiring on dispensers	○	○	○
Dispenser panels and covers secure	○	○	○
Electrical panel 36 in. clearance	○	○	○
No extension cords on forecourt	○	○	○

SIGNAGE & NO-SMOKING

	OK	NOT OK	N/A
No smoking signs at all dispensers	○	○	○
Turn off engine signs displayed	○	○	○
No cell phone signs posted	○	○	○
Emergency procedure signs legible	○	○	○
Fire action notice in store	○	○	○
Exit signs in store illuminated	○	○	○

FORECOURT HOUSEKEEPING

	OK	NOT OK	N/A
No fuel spills or staining on forecourt	○	○	○
Trash cans not overflowing	○	○	○
No combustible materials near dispensers	○	○	○
Vegetation trimmed away from equipment	○	○	○

CORRECTIVE ACTIONS

Deficiencies found

Assigned to _____

Inspector signature _____

Notes

Go digital with Miratag

Skip the paper — fill checklists faster on the Miratag mobile app. Add photos, videos, notes and signatures. Track compliance in real time. Start free at miratag.com

This template is a general-purpose resource, not tailored to any specific jurisdiction. Each organisation must validate compliance with local regulations.

Scan to view

Go digital with Miratag

Skip the paper — fill checklists faster on the Miratag mobile app. Add photos, videos, notes and signatures. Track compliance in real time. Start free at miratag.com

This template is a general-purpose resource, not tailored to any specific jurisdiction. Each organisation must validate compliance with local regulations.

Scan to view